



July 2017

Point Number	EPA Analyte	Guide Low Limit or Range Min	Guide High Limit or Range Max	Result
EPL#3	Aluminium	5	-	24
	Arsenic	0.5	-	<1
	BOD	30	-	<5
	Cadmium	0.01	-	<0.1
	Chemical oxygen demand	-	-	16
	Chromium	1	-	<1
	Cobalt	1	-	<1
	Conductivity	800	-	400
	Copper	0.4	-	1
	Fluoride	2	-	0.22
	Lead	0.1	-	1
	Manganese	-	-	1
	Mercury	0.002	-	<0.0001
	Molybdenum	0.15	-	1
	Nickle	1	-	1
	Oil and Grease	10	-	<5
	pH	6.5	8.5	8.7
	Selenium	0.02	-	<1
	Sulfate	-	-	160
	Total Suspended solids	50	-	<5
	Zinc	20	-	<5
	Cyanide	-	-	<0.004
	Methylene Blue Active Substance	-	-	0.2
EPL#4	Aluminium	5	-	24
	Arsenic	0.5	-	<1
	BOD	30	-	<5
	Cadmium	0.01	-	<0.1
	Chemical oxygen demand	-	-	16
	Chromium	1	-	<1
	Cobalt	1	-	<1
	Conductivity	800	-	480
	Copper	0.4	-	1
	Fluoride	2	-	0.23
	Lead	0.1	-	1
	Manganese	-	-	6
	Mercury	0.002	-	<0.0001
	Molybdenum	0.15	-	1
	Nickle	1	-	<1
	Oil and Grease	10	-	<5
	pH	6.5	8.5	8.8
	Selenium	0.02	-	<1
	Sulfate	-	-	180
	Total Suspended solids	50	-	<5
	Zinc	20	-	<5
	Cyanide	-	-	<0.004
	Methylene Blue Active Substance	-	-	<0.1
EPL#5	Aluminium	5	-	36
	Arsenic	0.5	-	<0.1
	BOD	30	-	<5

	Cadmium	0.01	-	<0.1
	Chemical oxygen demand	-	-	<10
	Chromium	1	-	<1
	Cobalt	1	-	<1
	Conductivity	800	-	680
	Copper	0.4	-	1
	Fluoride	2	-	0.36
	Lead	0.1	-	<1
	Manganese	-	-	12
	Mercury	0.002	-	<0.0001
	Molybdenum	0.15	-	2
	Nickle	1	-	<1
	Oil and Grease	10	-	<5
	pH	6.5	8.5	7.8
	Selenium	0.02	-	<1
	Sulfate	-	-	200
	Total Suspended solids	50	-	<5
	Zinc	20	-	<5
	Cyanide	-	-	<0.004
	Methylene Blue Active Substance	-	-	<0.1
EPL#6	Aluminium	5	-	280
	Arsenic	0.5	-	<1
	BOD	30	-	<5
	Cadmium	0.01	-	<0.1
	Chemical oxygen demand	-	-	12
	Chromium	1	-	<1
	Cobalt	1	-	<1
	Conductivity	800	-	410
	Copper	0.4	-	2
	Fluoride	2	-	0.16
	Lead	0.1	-	<1
	Manganese	-	-	5
	Mercury	0.002	-	<0.0001
	Molybdenum	0.15	-	2
	Nickle	1	-	<1
	Oil and Grease	10	-	<5
	pH	6.5	8.5	7.9
	Selenium	0.02	-	<1
	Sulfate	-	-	46
	Total Suspended solids	50	-	<5
	Zinc	20	-	<5
	Cyanide	-	-	<0.004
	Methylene Blue Active Substance	-	-	<0.1